


Class 0 Summary Report



Including Opinion Of Compliance With The Requirements For A Class 0 Surface As Defined In Paragraph A13(b) Of Approved Document B (Volumes 1 & 2), (2006 Edition) 'Fire Safety' To The Building Regulations 2000

Date: 16th July 2020

Issue No.: 1

Page 1

A Report To: Smyth Composites Ltd.
Document Reference: 426918 & 426919

Executive Summary

Objective To assess the results of tests to BS 476:Part 6:1989+A1: 2009 and BS 476:Part 7:1997, obtained on specimens of the following product and to provide an opinion of compliance with the requirements for a Class 0 surface, as defined in Approved Document B to the Building Regulations 2000.


Generic Description	Product reference	Thickness	Weight per unit area or density
Coated fibre reinforced phenolic resin sheet	"Phenclad"	3.7mm	3.9kg/m ²
Individual components used to manufacture composite:			
Two pack polyurethane paint	"AE 265/8"	20 microns	Unable to provide
Phenolic resin	"Cellobond"	Unable to provide	Unable to provide
Powder bound chopped strand mat	"Dong Yu"	Unable to provide	2 x 600g/m ²
Please see page 5 of this test report for the full description of the product tested			

Test Sponsor Smyth Composites Ltd, Unit 10, Panmure Industrial Estate, Carnoustie, Angus DD7 7NP


Opinion: We consider the results of the tests to BS 476:Part 6:1989+A1: 2009 (WF No. 426918) and BS 476:Part 7: 1997 (WF No. 426919) demonstrate that the product, as tested, complies with the requirements for Class 0, as defined in paragraph A13(b) of Approved Document B, 'Fire Safety', to the Building Regulations 2000.

Date of Test 6th & 16th March 2020

Signatories



Responsible Officer
 H Harper *
 Testing Officer



Authorised
 T. Deluce *
 Senior Technical Officer

* For and on behalf of [Warringtonfire](#).

Report Issued: 16th July 2020

This version of the report has been produced from a .pdf format electronic file that has been provided by [Warringtonfire](#) to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of [Warringtonfire](#).